

EF-overensstemmelseserklæring

EC Declaration of conformity



Fabrikant:
Manufacture:

Knudsen Køling A/S
Sandvadsvej 5
4600 Køge
Denmark
+45 5664 6363

Garantere og erklærer herved, at
Hereby ensures and declares that

Beskrivelse af det trykbærende udstyr
Description of the pressure equipment

Impulsmontre [IKR, IKM]

Fabrikations nr.:
Serial no:

300.000 - 500.000

Fabrikations år:
Year of manufacture:

2009 -

Tilladt minimal-/maksimaltryk:
Minimum/maximum allowable pressure:

[PS] 25 Bar

Tilladt minimal-/maksimaltemperatur:
Minimum/maximum allowable temperature:

[TS] - 40 / 40 °C

Fluida gruppe:
Fluida group:

II

Fluida:
Fluida:

R 404A

Andre tekniske specifikationer, der er anvendt:
Other technical standards and specifications used:

2006/42/EF

Andre fællesskabsdirektiver, der har fundet anvendelse:
References of the other Community Directives applied:

73/23/EF (evt. andre relevante)

Er fremstillet i overensstemmelse med EUROPA-PARLAMENTETS OG RÅDETS DIREKTIV 97/23/EF af 29. maj 1997 om indbyrdes tilnærmelse af medlemsstaternes lovgivning om trykbærende udstyr og andre fællesskabsdirektiver anført ovenfor.

Is manufactured in according with the DIRECTIVE 97/23/EC OF THE EUROPEAN PARLIAMENT AND OF THE COUNCIL of 29 May 1997 on the approximation of the laws of the Member States concerning pressure equipment and the other Community Directives stated above.

Navn, titel og underskrift for den underskriver der har fuldmagt til at forpligte fabrikanten:
Name, title and signature of the signatory authorized to sign the legally binding declaration for the manufacturer :

06.01.2010

R+D Manager

Finn Christensen

Dato / date

Titel / title

Navn / name